- Improper carrying or storage.
- Regarding to the service of replacement, returning and repairing, you need to retreat the product to our company, and we decide whether to replace or repair after we make clear who should be responsible.

## 8.4 We will not notice if there is any change of this product.

Solar Charge Controller with Maximum Power Point Tracking



Installation & Operation Manual

# Content

	Safety Instructions	. 5
2.	MPPT Controller Instructions	.6
	2.1 Overview	
	2.2 Structure	.6
	2.3 Functions	8
	2.4 MPPT technology Instructions	
3.	PV System Planning Reference	. 15
	3.1 System Voltage	. 15
	3.2 Solar Modules Configuration	
	3.3 Wire Sizing	
	3.4 Over Current Protection	19
	3.5 Lightning Protection	. 20

#### 8. Quality Assurance

- 8.1 Quality assurance should be carried out according to the following rules:
  - The product is guaranteed of replacement, returning and repairing within 7 days after sale.
  - The product is guaranteed of replacement and repairing within 1 month after sale.
  - The product is guaranteed of repairing within 12 months after sale.
- 8.2 If it is impossible to identify the using date of the controller, we would refer to the ex-work date, and prescribe 18 months as the warranty period. We need to charge beyond the warranty period. The controller can be repaired for life no matter when and where you use it.
- 8.3 If the controller is damaged by the following causes, we need to charge even if it is in the guarantee period:
- period.
- Do not operate according to the user's manual.
  Use the controller under the condition which is beyond the using standard and technical requirements.
- Repair by yourself or reform by yourself.
- The improper environmental condition which can cause the breakdown and aging of the apparatus.

0.8 Ka

Positive grounding

	Temperature compensation	-4mV/ cell/ C
	Battery type	Lead acid (GEL, AGM, Flooded)
Maximum efficiency		97%
	Human interface	LEDs, button
	Cooling style	Passive cooling
	Maximum wire size	10 mm <sup>2</sup>
	Ambient temperature range	-10 to +50 C
Other	Storage temperature range	-30 to +80 C
	Humidity	0 to 90%, no condensation
	Dimensions	118.5 x 188 x 54.5 mm

Note: Technical data at 25 C / 77 F

Degree of protection

Grounding

3.7 System Expansion 20

Operation Instructions 25 5.1 Button Function 25 

Faults and Remedies.

6.1 Protection Remedies.....

	6.2 Common Faults and Remedies	
7.	Technical Data	3
8.	Quality Assurance	3
_		
3		

ilation & Ope	ration Manual	VCISIOII
	Maximum PV voltage	≤70V
Input	MDD walks as near	12V~70V (12V)
	MPP voltage range	24V~70V (24V)
	System voltage	12V (24V)
	Maximum battery voltage	16V (32V)
	Maximum charging current	20A
	Maximum load current	20A
Output	Own consumption	≤15mA
Output –	Charging control mode	3-stage (Bulk, Absorption, Float)
	Float charge	13.8V (27.6V)
	Absorption charge	14.4V (28.8V), for 2 hours
	Load disconnection (LVD)	11.5V (23.0V)
	Load reconnection (LVR)	12.6V (25.2V)

#### 6.2 Common Faults and Remedies

Phenomenon	Cause	Remedy		
	The battery is connected	Check the fuse.		
LEDs no indication	to the controller with the	Disconnect the battery and reconnect it to the		
	wrong polarity. The fuse	controller with the correct polarity.		
burns out.				
Battery overvoltage The controller adjusts to		Disconnect the load, solar modules and battery.		
protection when the wrong system voltage		Waiting for about 10 seconds and then re-install the		
startup		controller.		
Stay in direct	The PV MPP voltage too	Its normal. If possible you can re-configure the PV		
charging mode	low. system to enlarge the PV open circuit voltage			

Technical Data

Dear Consumer:

Thank you very much for using our product! We will offer you the permanent and reliable service for your solar system!

The manual gives important recommendations for installing and using the MPPT controller. Please read the manual carefully and thoroughly before using this product.

- The controller is only designed to be connected to the off-grid solar system. It offers the management of charging and discharging for the lead-acid battery of flooded, gel and AGM chemistries from 12V to 24V nominal only. Do not connect this controller to other system, such as mains supply and windmill generator.
- The controller is intended for indoor use only. Protect it from direct sunlight and place it in a dry environment.
- Batteries generate explosive gases during normal operation. It is important never allow a spark or flame in vicinity of battery.
- Be sure to always keep children away from batteries and acid!
- Do not disassemble the MPPT controller, it does not have any user-serviceable parts.
- The controller warms up during normal operation. Do not touch the heatsink at the bottom of it.

Note: It is important that the battery is fully charged frequently (at least monthly). Otherwise the battery will be permanently damaged.

Installation & Operation	on Manual	Version 1.1
Load output Load off Rectify short circuit. Discor		Rectify short circuit. Disconnect and reconnect the load.
short circuit	Charging on	
Controller inside		Allow the controller to cool down. Check for possible causes of
		overheating (mounting location, other heat sources). Possibly reduce
		the charge current. Make sure the controller is adequately ventilated.
Inside		Disconnect the load, solar modules and battery. Re-install the
temperature	Load on	controller. If the error recurs, then please contact your specialist
sensor error Charging on		dealer.
	Load,	Disconnect the load, solar modules and battery. Re-install the
Self-test error	Charging	controller. If the error recurs, then please contact your specialist
	indefinite	dealer.

#### 6. Faults and Remedies

#### 6.1 Protection Remedies

Fault Phenomeno		Cause / Remedy
Battery voltage too low	Load off Charging on	Check the battery voltage and manually recharge the battery if necessary. Loads directly connected to the battery can cause deep discharge.
Battery voltage too high	Load off Charging off	Check installation. Check the battery voltage and check any additional charging sources if present.
PV voltage too high	Load on Charging off	Check the PV system configuration. The PV open circuit voltage increases while the ambient temperature decreases.
Excessive load current	Load off Charging on	Reduce the load current at the load output. The load may cause current peaks.

### 2. MPPT Controller Instructions

#### 2.1 Overview

MPPT 20A solar charge controller is multi-stage Maximum Power Point Tracking (MPPT) photovoltaic battery charge controller with our own technology. Its main topology adopts in Buck conversion circuit, and uses MCU to adjust the solar panels working point intelligently in order to make the solar panels output its maximum power. When the circumstances change, the working point of solar panels deviate from the maximum power point, MCU will adjust the solar panels working point based on MPPT calculation to make the solar panels back to the maximum power point again(refer to Chapter 2.4 about MPPT technology introduction). Compared with PWM controller, MPPT controller can increase the output power of solar panels by 5%~30%. The output power increasing proportion is affected by the factors such as solar panels property, humidity and light intensity. The controller uses wall-mount installing (refer to Chapter 4.1). Connecting terminal makes the wiring area bigger and wiring loss less.

#### 2.2 Structure




Figure 2-1: Controller Structure Diagram

## 5.3 System Voltage Indication

The MPPT 20A controller adjusts itself to 12V or 24V system voltage automatically. The system type indicates by the green led when the controller startup every time. Details show as follows:




Figure 5-3: System Voltage Indication Diagram

	Overvoltage Protection	∏_∏ T=1s
	Overtemperature Protection	
	Load Off	off
	Load On	illuminates
Load	Heatsink Temperature Sensor Error	T=2.2s
(Red)	Overload Protection	∏_∏ T=1s
	Load Short-circuit Protection	T=0.5s

#### 2.3 Functions

#### (1) Maximum Power Point Tracking technology

The controller uses Buck conversion circuit and MCU technology to track the maximum power point to implement the maximum output power of solar panels in different illumination intensity and temperature. The MPPT algorithm increases efficiency of your PV system and decreases the quantity of solar panels.

## (2) Multi-stage Charge Control

The starting charging voltage of battery is different, the controller will use the different charging strategies to finalize the charging process. When starting charging voltage of battery is lower than 12.4V (for 12V battery), battery will go through three stages as Bulk, Absorption and Float charging. When starting charging voltage of battery is higher than 12.4V (for 12V battery), battery will go through two stages as Bulk and Float charging.

# Bulk Charge:

The controller charges the battery by its maximum output current. It is at maximum power point tracking state at this phrase.

### Absorption Charge:

The controller begins to limit the charging current to make the battery voltage fixed at a settled absorption voltage (this voltage has temperature compensation) for 2 hours. It increases the charging saturation level of battery and prevents battery from leaking gas, and this can increase the lifetime of battery.

## Float Charge:

The battery is at saturation state, and the controller charges the battery at a trickle current to make the battery voltage fixed at the settled float charging voltage (this voltage has temperature compensation).




Figure 2-2: Three-stage Charge




Figure 2-3: Two-stage Charge

# (3) Charge Voltage Temperature-compensated

then the load will be switched off. This can also switch on the load.

#### 5.2 LED Displays

LED	Meaning	Status
	PV Voltage Low	off
	MPPT Charge	illuminates
Solar	Absorption Charge	T=2s
(Red)	Float Charge	∏_∏ T=1s
	PV Overvoltage Protection	T=0.5s
	Battery Disconnect	off
Battery	Normal Operation	illuminates
(Green)	Undervoltage Protection	T=2s

Version 1.1

based on the current battery temperature.

For 12V battery, the compensated voltage U=(t-25)\*6\*(-0.004)V For 24V battery, the compensated voltage U=(t-25)\*12\*(-0.004)V

# (4) Discharge Control

The controller monitors the battery voltage all the time. The load will be switched off when the voltage less than the Low Voltage Disconnect (LVD) point, and it wont be switched on until the voltage more than the Low Voltage Reconnect (LVR) point.

# (5) Protection against Reverse Connected Battery

Connecting the battery to the controller by reversed polarity (under the circumstances of solar panels disconnected) will not damage the controller. The controller will work normally after connecting with correct polarity.

# (6) Protection against Reverse Connected Solar Modules

Connecting the solar modules with the controller by reserved connection will not damage the controller. The controller will work normally after connecting with correct polarity.

B. Check whether the battery voltage and solar panels array voltage is within the requested range.

C. Switch off the over-current breaker or fuse of the battery, solar panels array and load.

D. Wiring.

(1) Connect the battery with the battery terminal on the controller by cables and fasten the screws.

(2) Connect the load with the load terminal on the controller by cables and fasten the screws.

(3) Connect the solar panels array with the PV terminal on controller by cables and fasten the screws.

E. Switch on the breaker or fuse of the battery, then the 3 indicators indicate the system status. Switch on the breaker or fuse of the load. (more information about the indicators see Chapter 5.2 and 5.3)

F. Switch on the breaker or fuse of the battery, then the controller starts to charge the battery.

## Operation Instructions

#### 5.1 Button Function

There is only one concealed button on the controller, which used to restart the load when the controller is in overload protection state. The second function of the button is to control the load. Press the button and hold about 3 seconds.

#### (7) Reverse Current Protection

The controller prevents reverse current from flowing into the solar modules at night. An additional reverse current diode is not required.

## (8) Overtemperature Protection

If the temperature inside the controller becomes too high, then the controller will stop charging to the battery. and it will restart charging the battery again when the temperature decreases to a certain value.

## (9) PV Overvoltage Protection

If the input voltage of solar panels exceeds the maximum voltage permitted by the controller, it will enter into protection state automatically and stop charging. When the input voltage recovers to the normal range, the controller will start charging again.

# (10) Current-limited for Excessive Charging Current

If the permissible charge current is exceed, the controller will deviate from the maximum power point to limit the output current to prevent the controller being damaged.

(11) Load Output Overload Protection If the permissible load current is exceed, then the load output is switched off. The overload current vs. duration

#### 4.3 Wiring

- Choose the appropriate cables requested as Chapter 3. Prepare 4 sets of M5 screws (used to fix the controller on the wall or other vertical plane).
- Prepare cutting pliers, cross screwdriver and multi-meter, etc.

## 4.4 Installation Process



**Note:**Please switch off the breakers of battery, solar panels array before installing the controller. Do not touch the positive and negative pole of solar panels or battery at the same time when installing, otherwise you have the risk of electrical shock.

A. Mount the controller on the wall and fasten the screws.

#### 4.2 Connecting Diagram




Figure 4-2: Connecting Diagram

shows as follows:

The controller restarts the load every 5 minutes automatically, but the user can also restart the load by the Reset key.

· · · · · · · · · · · · · · · · · · ·				
Rate of Current	Duration (s)			
1.1Irate ≤I< 1.2Irate	120			
1.2Irate ≤l< 1.5Irate	60			
1.5lrate ≤l< 1.8lrate	10			
l≥ 1.8Irate	0.2			
Note: Irate=20A, nominal load current				

# 2.4 MPPT technology Instructions

Solar panels are nonlinear materials, and the output power is mainly affected by illumination intensity, solar panels temperature and load impedance. When the illumination intensity and solar panels temperature are fixed, the output power of solar panels is only affected by load impedance. Different load impedance makes the solar panels work at different point and put out different power. The following figure marks the points A, B, C, D, and the

working point features as follows:

### Working point D:

Output voltage is 22.3V, output power is 0W. This point is the open circuit point of solar panels.

# Working point C:

Output voltage is 0V, output power is 0W. This point is the short circuit working point of solar panels.

## Working point A:

Output voltage is 13V, output power is 74W. This working point is the state when using normal controller, and the solar panels voltage is clamped to 13V by battery.

## Working point B:

Output voltage is 17.6V, output power is 92W. This point is the state when using MPPT controller. Because of using power conversion technology, the solar panels voltage is not clamped by battery and still works at maximum power point.

Compare working point A & B, it is easy to find using MPPT controller can increase the using efficiency of solar panels. Compared to normal controller, MPPT controller can generate more power.

4.1 Dimensions




Figure 4-1: Dimensions (Unit: mm) Mounting hole pitch: 86mm\*178mm Mounting hole diameter: Ф5mm Height\*Width\*Thickness: 118.5mm\*188mm\*54.5mm Connecting terminals: Maximum 10mm<sup>2</sup>

#### 4. Installation



- 1. Protect the controller from direct sunlight or other source of heat.
- 2. Place the controller in a dry environment.
- 3. A free space of at least 15cm on all side of the controller must be
- provided.

  4. Mount the controller as close as possible to the batteries.





Figure 2-4: Voltage-Current Curve



# PV System Planning Reference

# 3.1 System Voltage

## Figure 2-5: Voltage-Power Curve

## 3.5 Lightning Protection

It is the same as other electrical devices that MPPT 20A controller will be damaged by lightning. The controller has limited surge absorption capacity. We strongly suggest users to install lightning surge absorption devices to increase the reliability of the system.

# 3.6 Grounding

Use 4 mm<sup>2</sup> yellow and green cable to connect any of the positive terminal of the controller to the ground bus of the system. This can decrease the electromagnetic interference in a certain value.

# 3.7 System Expansion

If you want to deploy a bigger system, you can expand the system by paralleling several sets of the same controller. More controllers can share with one battery group, but each controller must be connected with the independent solar panels array and the independent load. (Please contact the local distributor for further information.)

The following is the cable length between solar panels and controller, and also the suggested copper cables:

ı r	The following is the cable length between solar panels and controller, and also the suggested copper cables:						
	Cable	Cable Size	Cable Size in	Voltage Loss	Solar F	Panels Voltag	je Loss
	Length	in mm²	AWG	at 20A (a pair)	17V	34V	68V
	2m	4mm <sup>2</sup>	#11 AWG	0.35V	2.1%	1.03%	0.50%
	4m	6mm <sup>2</sup>	#9 AWG	0.48V	2.8%	1.41%	0.71%
	8m	10mm <sup>2</sup>	#7 AWG	0.58V	3.4%	1.71%	0.85%

Table 3-5: Cable Length & Cable Voltage Drop

### 3.4 Over Current Protection

The electrical equipment used in power circuit must be equipped with over current and short-circuit protection devices, and there is no exception for MPPT 20A controller. The controller adopts in the design of common positive pole inside. We suggest users to install over-current breaker or fuse on the negative loop of solar panels input, and also the negative loop of battery output. The capacity of over-current breaker or fuse is 1.25 times of the rated current.

The common system voltage of solar system has 3 types: 12V, 24V and 48V. The higher the system voltage, the more power the system can handle. In reality application, user should consider the load power, and the voltage scope permitted by load, and then confirms which system voltage you should use. The power range for each system voltage is as follows:

 tom rollago lo do follo fol					
System Voltage	Recommended Power Range				
12V	<800W				
24V	<2000W				
48V	<6000W				

Table 3-1: System voltage vs. Power range

# 3.2 Solar Modules Configuration

Model	Category	Pmax	Voc	Isc	Vpmax	Ipmax
STP140D-12/TEA	Single Crystalline Silicon Module	140W	22.4V	8.33A	17.6V	7.95A
MS140GG-02	Thin-film Module	140W	29.0V	7.12A	23.0V	6.52A

#### Single Crystalline 190W 45.2V 5.65A 36.6V 5.2A STP190S-24/Ad+ Silicon Module 130W 60.4V 46.1V 2.82A NS-F130G5 Thin-film Module 3.41A The above parameters are for condition of 25 C, AM1.5 spectrum, and 1000W/m<sup>2</sup> illumination intensity.

Table 3-2: Solar Panels Model and Parameters

Model	For 12V System	For 24V System	For 48V System		
STP140D-12/TEA	N in parallel	two in series, N in parallel	four in series, N in parallel		
MS140GG-02	N in parallel	two in series, N in parallel	four in series, N in parallel		
STP190S-24/Ad+	Ad+ N in parallel N in paralle		two in series, N in parallel		
NS-F130G5	two in series, N in parallel				
N means the quantity number required by the output current.					

Table 3-3: Solar Panels Model and System Configuration Solution

3.3 Wire Sizing

The maximum input and output current of the controller is 20A. To ensure the cable temperature does not exceed the safety range, the copper cables area must be at least 4 mm<sup>2</sup>. In reality application, user can choose the appropriate cables according to the system voltage, permitted cable temperature, cable voltage drop and also cable material. We suggest customer to control the maximum battery voltage loss under 1.5%, and control the maximum voltage loss of solar panels under 2.5%.

The following is the cable length between controller and battery, and the suggested conner cables:

The following is the cable length between controller and battery, and the suggested copper cables.								
	Cable	Cable Size in	Cable Size in	Voltage Loss	Battery Voltage Loss			
	Length	mm²	AWG	at 20A (a pair)	12V	24V	48V	
	1m	4mm <sup>2</sup>	#11 AWG	0.18V	1.5%	0.75%	0.35%	
	2m	6mm <sup>2</sup>	#9 AWG	0.24V	2.0%	1.0%	0.50%	
	4m	10mm <sup>2</sup>	#7 AWG	0.29V	2.4%	1.2%	0.61%	

Table 3-4: Cable Length & Cable Voltage Drop